



COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY

NORTHERN REGIONAL OFFICE

Douglas W. Domenech
Secretary of Natural Resources

13901 Crown Court, Woodbridge, Virginia 22193
(703) 583-3800 Fax (703) 583-3821
www.deq.virginia.gov

David K. Paylor
Director

Thomas A. Faha
Regional Director

April 5, 2012

Mr. Robert Propst
Site Supervisor
Lake Anna Environmental Services, Inc.
Lake Anna Environmental Services STP
200 Lake Front Drive, Suite 103
Lake Anna, VA 23117

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Re: Reissuance of Virginia Pollutant Discharge Elimination System (VPDES) Permit No. VA0072079
Lake Anna Environmental Services STP, Louisa County

Dear Mr. Propst:

The Department of Environmental Quality (DEQ) has approved the enclosed effluent limitations and monitoring requirements for the above-referenced permit. Copies of your permit and fact sheet are enclosed.

A Discharge Monitoring Report (DMR) form is no longer included in the reissuance package. The first electronic DMR submittal for the monthly monitoring period beginning April 5, 2012, is due by May 10, 2012. Please reference the effluent limits in your permit and report monitoring results in e-DMR to the same number of significant digits as are included in the permit limits for the parameter.

With this reissuance DEQ-NRO is launching a self-certification approach for O&M Manual approvals. We expect every permittee to self-certify their O&M Manual status as permits are reissued. The application for self-certification is enclosed. The application is to be signed and submitted by the permittee. This submission is due no later than July 5, 2012. Please note that DEQ staff maintains the ability to review and comment on the O&M Manual with inspections and to require updates to the O&M Manual as warranted.

Please note that compliance with the permit's requirements for use and disposal of sewage sludge do not relieve you of your responsibility to comply with federal requirements set forth in 40 CFR Part 503. Until DEQ seeks and is granted authority to administer the Part 503 regulations by EPA, treatment works treating domestic sewage should continue to work directly with EPA to comply with them.


As provided by Rule 2A:2 of the Supreme Court of Virginia, you have thirty days from the date of service (the date you actually received this decision or the date it was mailed to you, whichever occurred first) within which to appeal this decision by filing a notice of appeal in accordance with the Rules of the Supreme Court of Virginia with the Director, Department of Environmental Quality. In the event that this decision is served on you by mail, three days are added to that period.

Alternately, any owner under §§ 62.1-44.16, 62.1-44.17, and 62.1-44.19 of the State Water Control Law aggrieved by any action of the State Water Control Board taken without a formal hearing, or by inaction of the Board, may demand in writing a formal hearing of such owner's grievance, provided a petition requesting such hearing is filed with the Board. Said petition must meet the requirements set forth in §1.23(b) of the Board's Procedural Rule No. 1. In cases involving actions of the Board, such petition must be filed within thirty days after notice of such action is mailed to such owner by certified mail.

The 0.020 MGD permitted treatment works shall meet Reliability Class II. Upon issuance of the Certificate to Operate for the 0.099 MGD flow tier, the permitted treatment works shall meet Reliability Class I. Additionally, this facility has Class IV licensed operator requirements at the 0.020 flow tier and Class III licensed operator requirements upon issuance of the Certificate to Operate for the 0.099 MGD flow tier.

If you have questions about the permit, please contact Susan Mackert at (703) 583-3853, or by E-mail at susan.mackert@deq.virginia.gov.

Respectfully,



Bryant Thomas
Water Permits Manager

Enc.: Application for Operations and Maintenance Manual Approval
Permit for VA0072079
Fact Sheet for VA0072079

cc: DEQ-Water, OWPP
EPA-Region III, 3WP12
Department of Health, Culpeper
Water Compliance, NRO